

Certificate of Assessment

NK5857

No 1252

"Copyright CSIRO 2009 ©"
Copying or alteration of this report
without written authorisation from CSIRO is forbidden.

This is to certify that the specimen described below was tested by the CSIRO Division of Materials Science and Engineering in accordance with Australian/ New Zealand Standard 3837, Method of test for heat and smoke release rates for materials and products using an oxygen consumption calorimeter, 1998, at 50 kW/m², on behalf of:

Corporate Culture Australia Pty Ltd
21-23 Levey Street
Chippendale NSW
AUSTRALIA

A full description of the test specimen and the complete test results are detailed in the Division's sponsored investigation report numbered FNK 9408.

SAMPLE
IDENTIFICATION: Soundwave Acoustic Panel

DESCRIPTION OF
SAMPLE: The sponsor described the tested specimen as a recycled PET needle felt panel consisting of polyester and bi-component polyester fibres.

Nominal total thickness: 6 mm
Nominal mass: 0.06 kg/m²
Colour: Off white

SAMPLE
CLASSIFICATION: Group Number: Group 4
(In accordance with Specification A2.4 of the Building Code of Australia.)
Average specific extinction area: 471.4 m²/kg
(Refer to Specification C1.10a section 3(c) of the Building Code of Australia.)

Testing Officer: Russell Collins Date of Test: 25 May 2009 / 28 May 2009

Issued on the 05th day of June 2009 without alterations or additions.



Garry E Collins
Manager, Fire Testing and Assessments



CSIRO Materials Science and Engineering
14 Julius Avenue, Riverside Corporate Park, North Ryde NSW 2113 AUSTRALIA
Telephone: 61 2 9490 5444 Facsimile: 61 2 9490 5555

Certificate of Assessment

NK5857

No 1252

"Copyright CSIRO 2009 ©"
Copying or alteration of this report
without written authorisation from CSIRO is forbidden.

This is to certify that the specimen described below was tested by the CSIRO Division of Materials Science and Engineering in accordance with Australian/ New Zealand Standard 3837, Method of test for heat and smoke release rates for materials and products using an oxygen consumption calorimeter, 1998, at 50 kW/m², on behalf of:

Corporate Culture Australia Pty Ltd
21-23 Levey Street
Chippendale NSW
AUSTRALIA

A full description of the test specimen and the complete test results are detailed in the Division's sponsored investigation report numbered FNK 9408.

SAMPLE

IDENTIFICATION: Soundwave Acoustic Panel

DESCRIPTION OF SAMPLE:

The sponsor described the tested specimen as a recycled PET needle felt panel consisting of polyester and bi-component polyester fibres.

Nominal total thickness: 6 mm
Nominal mass: 0.06 kg/m²
Colour: Off white

SAMPLE

CLASSIFICATION: Group Number: Group 4
(In accordance with Specification A2.4 of the Building Code of Australia.)
Average specific extinction area: 471.4 m²/kg
(Refer to Specification C1.10a section 3(c) of the Building Code of Australia.)

Testing Officer: Russell Collins Date of Test: 25 May 2009 / 28 May 2009

Issued on the 05th day of June 2009 without alterations or additions.



Garry E Collins
Manager, Fire Testing and Assessments



CSIRO Materials Science and Engineering
14 Julius Avenue, Riverside Corporate Park, North Ryde NSW 2113 AUSTRALIA
Telephone: 61 2 9490 5444 Facsimile: 61 2 9490 5555