


**SOUND ABSORPTION AREA FOR OBJECT**

Measured and evaluated according to SS-EN ISO 354 and ISO 20189

Client:	Abstracta		
Object:	Trumpet 1040		
Size [mm]:	w = 515	h = 1040	d = 80

1/3 octave band (Hz)	Equivalent sound absorption area / unit (m <sup>2</sup> Sabine)
63	0.08
125	0.1
250	0.4
500	0.5
1000	0.5
2000	0.5
4000	0.6
N <sub>10</sub> = 20	

**CONDITIONS**

Date of test:	2017-05-10	Object volume:	0.04	m <sup>3</sup>
Date:	2020-03-24	Rev. room volume:	200	m <sup>3</sup>

Test report: Akustikverkstan report 17-094-R1  
 Signature: Delphine Bard