


# SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to SS-EN ISO 354 and ISO 20189

Client:	Abstracta		
Object:	Trumpet 2040		
Size [mm]:	w = 515	h = 2040	d = 80

1/3 octave band (Hz)	Equivalent sound absorption area / unit (m <sup>2</sup> Sabine)
63	0.1
125	0.2
250	0.8
500	0.9
1000	1
2000	1.1
4000	1.2
N <sub>10</sub> = 11	



## CONDITIONS

Date of test:	2017-05-10	Object volume:	0.08	m <sup>3</sup>
Date:	2020-03-24	Rev. room volume:	200	m <sup>3</sup>

Test report: Akustikverkstan report 17-094-M13  
 Signature: Delphine Bard